

CONSUMER CONFIDENCE REPORT 2018 CITY OF FLAT ROCK

Drinking water quality is important to our community and the region. The City of Flat Rock and the Great Lakes Water Authority (GLWA) are committed to meeting state and federal water quality standards including the Lead and Copper Rule. With the Great Lakes as our water source and proven treatment technologies, the GLWA consistently delivers safe drinking water to our community. Flat Rock operates the system of water mains that carry this water to your home's service line. This year's Water Quality Report highlights the performance of GLWA and Flat Rock water professionals in delivering some of the nation's best drinking water. Together, we remain committed to protecting public health and maintaining open communication with the public about our drinking water.

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The Flat Rock Water Department and the Detroit Water and Sewerage Department vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum level or any other water quality standard.

Why are there contaminants in my drinking water?

"Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health."

Do I need to take special precautions?

"Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care

providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)."

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

Lead Contamination in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Flat Rock is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Where does my water come from?

Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes was determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

GLWA initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. GLWA participates in a National Pollutant Discharge Elimination System permit discharge program and has an emergency response management plan. In 2015 GLWA received a grant from The Michigan Department of Environmental Quality to develop a source water protection program for the Detroit River intakes. The programs include seven elements that include the following: roles and duties of government units and water supply agencies, delineation of a source water protection area, identification of potential of source water protection area, management approaches for protection, contingency plans, siting of new sources and public participation. If you would like to know more information about the Source Water Assessment report or a complete copy of this report please, contact your water department (734) 782-2470

Cryptosporidium

The Great Lakes Water Authority monitored for *Cryptosporidium* in our source water (Detroit River) at our Southwest Water Treatment Plant during 2016. *Cryptosporidium* was detected twice in our source water samples. A follow-up water sample was collected from the treated water and *Cryptosporidium* was not found to be present. *Cryptosporidium* is a microbial pathogen found in surface water throughout the U.S. Although filtration removes *Cryptosporidium*, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immunocompromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water."

Safe drinking water is a shared responsibility. The water that GLWA delivers to our community does not contain lead. Lead can leach into drinking water through home plumbing fixtures, and in some cases, customer service lines. Corrosion control reduces the risk of lead and copper from leaching into your water. Orthophosphates are added during the treatment process as a corrosion control method to create a protective coating in service pipes

throughout the system, including in your home or business. The City of Flat Rock performs required lead and copper sampling and testing in our community. Water consumers also have a responsibility to maintain the plumbing in their homes and businesses, and can take steps to limit their exposure to lead.

You can save hundreds, even thousands, of gallons of water each day by making adjustments in daily routines. Install a faucet aerator to save 1-3 gallons of water per minute of use. A low flow shower head can save you 10 gallons of water per minute which is an average of 20,000 gallons a year. Watch for any drips in faucets. A running toilet can waste up to 74,000 in just 3 months.

The City of Flat Rock and the Great Lakes Water Authority are committed to safeguarding our water supply and delivering quality drinking water to protect public health. Please contact us with any questions or concerns about your water.

If you have any questions or comments, contact:

James M. Lancaster
Director of Public Services
25500 Gibraltar Rd.
Flat Rock, MI 48134
(734) 782-2470

**Southwest Water Treatment Plant
2018 Regulated Detected Contaminants Tables**

2018 Inorganic Chemicals – Monitoring at the Plant Finished Water Tap

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Fluoride	6-12-2018	ppm	4	4	0.66	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	6-12-2018	ppm	10	10	0.41	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium	5-16-2017	ppm	2	2	0.01	n/a	no	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

2018 Disinfection By-Products – Monitoring in Distribution System, Stage 2 Disinfection By-Products

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Allowed Level MCL	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2018	ppb	n/a	80	.34	.34	NO	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2018	ppb	n/a	60	.12	.12	NO	By-product of drinking water disinfection

2018 Disinfectant Residuals – Monitoring in Distribution System by Treatment Plant

Regulated Contaminant	Test Date	Unit	Health Goal MRDLG	Allowed Level MRDL	Highest RAA	Quarterly Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2018	ppm	4	4	0.58	0.48-0.61	no	Water additive used to control microbes

2018 Turbidity – Monitored every 4 hours at Plant Finished Water

Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.19 NTU	100 %	no	Soil Runoff

Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

2017 Lead and Copper Monitoring at Customers' Tap

Regulated Contaminant	Test Date	Unit	Health Goal MCLG	Action Level AL	90 th Percentile Value*	Number of Samples over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2017	ppb	0	15	0 PPB	0	NO	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2017	ppm	1.3	1.3	.2 PPM	0	NO	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

**Southwest Water Treatment Plant
2018 Regulated Detected Contaminants Tables**

Regulated Contaminant	Treatment Technique 2018	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no TOC removal requirement	Erosion of natural deposits

Radionuclides 2014

Regulated contaminant	Test date	Unit	Health Goal MCLG	Allowed Level	Level detected	Violation Yes/no	Major Sources in Drinking water
Combined Radium 226 and 228	5-13-14	pCi/L	0	5	0.65 + or - 0.54	no	Erosion of natural deposits

Contaminant	MCLG	MCL	Level Detected 2018	Source of Contamination
Sodium (ppm)	n/a	n/a	6.36	Erosion of natural deposits

GLWA voluntarily monitors for Cryptosporidium and Giardia in our untreated source water monthly. The untreated water samples collected from our Southwest plant indicated the presence of one Giardia cyst in March. In addition, monitoring indicated the presence of one Giardia cyst and one Cryptosporidium oocyst in the untreated water from the Southwest plant in July. Additional testing was performed on the treated water at the Southwest plant and Cryptosporidium was absent. All other samples collected in the year 2018 were absent for the presence of Cryptosporidium and Giardia. Systems using surface water like GLWA must provide treatment so that 99.9 percent of Giardia lamblia is removed or inactivated.

Cryptosporidium is a microbial parasite found in surface water throughout the United States. Although Cryptosporidium can be removed by filtration, the most commonly used filtration cannot guarantee 100% removal. Current test methods do not enable us to determine if these organisms are dead or alive. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy persons can overcome the disease within a few weeks. However, immuno-compromised people (such as those with AIDS, undergoing chemotherapy or recent organ transplant recipients) are at a greater risk of developing a severe, life-threatening illness. Immuno-compromised persons should contact their doctor to learn about appropriate precautions to prevent infection. Cryptosporidium must be taken in through the mouth to cause disease and it may be passed by other means than drinking water.

Key to the Detected Contaminants Table

Symbol	Abbreviation	Definition/Explanation
>	Greater than	
°C	Celsius	A scale of temperature in which water freezes at 0° and boils at 100° under standard conditions.
AL	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAA5	Haloacetic Acids	HAA5 is the total of bromoacetic, chloroacetic, Dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
Level 1	Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in the water system.
Level 2	Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
LRAA	Locational Running Annual Average	The average of analytical results for samples at a particular monitoring location during the previous four quarters.
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
MRDL	Maximum Residual Disinfectant Level	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRLDG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
n/a	not applicable	
ND	Not Detected	
NTU	Nephelometric Turbidity Units	Measures the cloudiness of water.
pCi/L	Picocuries Per Liter	A measure of radioactivity
ppb	Parts Per Billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
ppm	Parts Per Million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
RAA	Running Annual Average	The average of analytical results for all samples during the previous four quarters.
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
TTHM	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.
μohms	Microhms	Measure of electrical conductance of water



**Great Lakes Water Authority
Water Quality**

**DISTRIBUTION AND BRACKETING - BRACKETING POINTS FOR A TOWN
Town: FLAT ROCK**

<u>Date</u>	<u>Removed</u>	<u>Pt.</u>	<u>Location</u>	<u>Address</u>
		1	Flat Rock Police Station - Utility sink	25500 Gibraltar Rd.
		A	Sewer Pumping Station	25104 Gibraltar Road
		B	Arbor Drug Store	25702 Gibraltar Road
01/13/2012	2		City Mechanic Garage - Restroom	26647 W. Huron River Dr., West End Of City
01/13/2012		A	unknown	26643 W. Huron River Drive
01/13/2012		B	Grapevine Craft Store	26658 W. Huron River Drive
		3	Flat Rock Community Center - staff break room tap	1 Maguire St.
		A	Sleep Inn	29101 Commerce Dr.
		B	Gerotech Corporation	29200 Commerce Dr.
		4	John's Garage-Restroom utility sink	26810 Telegraph Road
		A	Tom's Collision (wash sink at front of shop)	26813 Telegraph
		B	Autozone Auto Parts (slop sink at back of store)	26681 Telegraph

Total number of distribution Point numbers :4

Total number of distribution Point numbers in Service :3

Total number of Bracket Point numbers : 8

Total number of Bracket Point numbers in Service :6



Great Lakes Water Authority
Water Quality

RESULTS (BY TOWN) 01/01/2018 To 12/31/2018

<u>Date</u>	<u>Pt.</u>	<u>Br.</u>	<u>Sample #</u>	<u>T. Coliform</u>	<u>E. Coll</u>	<u>Cl2</u>	<u>Need Recheck</u>	<u>Recheck Date</u>
<u>Town Name: Flat Rock</u>								
01/04/2018	3	-	35	-	-	0.57		
01/10/2018	1	-	29	-	-	0.36		
01/17/2018	4	-	6	-	-	0.75		
01/23/2018	3	-	35	-	-	0.52		
02/06/2018	3	-	48	-	-	0.44		
02/08/2018	1	-	58	-	-	0.28		
02/13/2018	4	-	6	-	-	0.68		
02/21/2018	3	-	13	-	-	0.69		
03/01/2018	3	-	18	-	-	0.55		
03/14/2018	1	-	6	-	-	0.39		
03/21/2018	4	-	52	-	-	0.69		
03/28/2018	3	-	6	-	-	0.53		
04/06/2018	3	-	35	-	-	0.54		
04/12/2018	1	-	10	-	-	0.16		
04/17/2018	4	-	39	-	-	0.63		
04/26/2018	3	-	16	-	-	0.46		
05/08/2018	3	-	6	-	-	0.71		
05/15/2018	1	-	23	-	-	0.11		
05/17/2018	4	-	6	-	-	0.64		
05/23/2018	3	-	31	-	-	0.62		
06/05/2018	3	-	39	-	-	0.54		
06/11/2018	1	-	44	-	-	0.12		
06/15/2018	4	-	14	-	-	0.62		
06/27/2018	3	-	53	-	-	0.60		
07/02/2018	3	-	5	-	-	0.40		



Great Lakes Water Authority
Water Quality

RESULTS (BY TOWN) 01/01/2018 To 12/31/2018

<u>Date</u>	<u>Pt.</u>	<u>Br.</u>	<u>Sample #</u>	<u>T. Colliform</u>	<u>E. Coll</u>	<u>Cl2</u>	<u>Need Recheck</u>	<u>Recheck Date</u>
07/11/2018	1	-	48	-	-	0.11		
07/17/2018	4	-	29	-	-	0.61		
07/24/2018	3	-	14	-	-	0.39		
08/07/2018	3	-	29	-	-	0.34		
08/10/2018	1	-	34	-	-	0.22		
08/22/2018	1	-	39	-	-	0.11		
08/23/2018	3	-	29	-	-	0.29		
09/07/2018	3	-	25	-	-	0.38		
09/11/2018	1	-	25	-	-	0.14		
09/19/2018	4	-	6	-	-	0.68		
09/25/2018	3	-	13	-	-	0.39		
10/03/2018	3	-	38	-	-	0.50		
10/10/2018	1	-	56	-	-	0.03		
10/17/2018	4	-	6	-	-	0.70		
10/25/2018	3	-	16	-	-	0.43		
11/01/2018	1	-	31	-	-	0.28		
11/08/2018	1	-	27	-	-	0.22		
11/16/2018	4	-	6	-	-	0.79		
11/28/2018	3	-	55	-	-	0.59		
12/04/2018	3	-	32	-	-	0.55		
12/05/2018	1	-	49	-	-	0.11		
12/12/2018	3	-	66	-	-	0.77		
12/14/2018	3	-	6	-	-	0.63		

Total No. of Samples Collected: 48